

Message

From: Dennis Garbiel [dgarbiel@facil.umass.edu]
Sent: 4/26/2012 3:38:30 PM
To: Ewart, Burt [bewart@facil.umass.edu]; Roberts, Juan [/O=COMMONWEALTH OF MASSACHUSETTS/OU=MassMail-01/cn=Recipients/cn=JuanRoberts]
CC: Hanchett, James (DPH) [/O=COMMONWEALTH OF MASSACHUSETTS/OU=MassMail-01/cn=Recipients/cn=James.Hanchett]
Subject: RE: Exhaust Failure at DPH Lab, Morrill I N236- WO 6041

The motor has been removed and a new one will be installed .Has been ordered. Hopefully back-up tomorrow or monday

From: Ewart, Burt
Sent: Thursday, April 26, 2012 10:44 AM
To: Dennis Garbiel; Juan Roberts
Cc: Jim Hanchett (James.Hanchett@state.ma.us)
Subject: FW: Exhaust Failure at DPH Lab, Morrill I N236- WO 6041

Denny and Juan,

I don't know who to show this to – apparently a Plant HVAC maintenance person is having some trouble finding the exhaust fan to the Drug Lab? Last I checked – it was where it has always been...

One of you might want to follow up with Jim Hanchett there...

Burt

Burt Ewart

Capital Project Manager
University of Massachusetts
Facilities Planning Division
360 Campus Center Way
Amherst, MA 01003-9248

bewart@facil.umass.edu

Direct Extension: 413.577.0128
Mobile: [REDACTED]
Office Main: 413.545.1383
Fax: 413.545.3684

From: Hanchett, James (DPH) [mailto:james.hanchett@state.ma.us]
Sent: Thursday, April 26, 2012 10:37 AM
To: Ewart, Burt
Subject: RE: Exhaust Failure at PDH Lab, Morrill I N236

I put in a work order to Physical Plant # 6041 and some one from maintenance came and check it out. He said he could not find it.

Jim

From: Ewart, Burt [<mailto:bewart@facil.umass.edu>]
Sent: Thursday, April 26, 2012 10:12 AM
To: Hanchett, James (DPH)
Subject: RE: Exhaust Failure at PDH Lab, Morrill I N236

Jim,

I checked the original drawings. It looks like your lab area, including the hood at the east end of the room, is directly connected to what is noted as Exhaust Fan 7. That fan is to the west and south of the elevator shaft in the roof penthouse, and it exhausts through a louver on the south face of the penthouse. It definitely was not in the scope of (or was otherwise touched by) the Vivarium project, or your office remodel. Plant may not be able to "find" it on their computer screens – I have no information here whether this fan was ever upgraded to DDC controls or monitored by the central controls office. But it does exist.

Who did you talk to at Plant?

Burt

Burt Ewart

Capital Project Manager
University of Massachusetts
Facilities Planning Division
360 Campus Center Way
Amherst, MA 01003-9248

bewart@facil.umass.edu

Direct Extension: 413.577.0128
Mobile: [REDACTED]
Office Main: 413.545.1383
Fax: 413.545.3684

From: Hanchett, James (DPH) [<mailto:james.hanchett@state.ma.us>]
Sent: Thursday, April 26, 2012 10:00 AM
To: Ewart, Burt
Subject: RE:

Thanks,

Jim

From: Ewart, Burt [<mailto:bewart@facil.umass.edu>]
Sent: Thursday, April 26, 2012 9:52 AM
To: Hanchett, James (DPH)
Subject: RE:

OK, I'll do some research. This is odd...

Burt Ewart

Capital Project Manager
University of Massachusetts
Facilities Planning Division
360 Campus Center Way
Amherst, MA 01003-9248

bewart@facil.umass.edu

Direct Extension: 413.577.0128
Mobile: [REDACTED]
Office Main: 413.545.1383
Fax: 413.545.3684

From: Hanchett, James (DPH) [<mailto:james.hanchett@state.ma.us>]
Sent: Thursday, April 26, 2012 9:51 AM
To: Ewart, Burt
Subject: RE:

I did and they could not find it.

From: Ewart, Burt [<mailto:bewart@facil.umass.edu>]
Sent: Thursday, April 26, 2012 9:50 AM
To: Hanchett, James (DPH)
Subject: RE:

Hi, Jim,

I don't think so – You should put in a Service Request to Physical Plant if it's not working.

Burt

Burt Ewart

Capital Project Manager
University of Massachusetts
Facilities Planning Division
360 Campus Center Way
Amherst, MA 01003-9248

bewart@facil.umass.edu

Direct Extension: 413.577.0128
Mobile: [REDACTED]
Office Main: 413.545.1383
Fax: 413.545.3684

From: Hanchett, James (DPH) [<mailto:james.hanchett@state.ma.us>]

Sent: Thursday, April 26, 2012 9:42 AM

To: Ewart, Burt

Subject:

Hi Burt,

Did you disable the exhaust blower for room N236 when you did renovations for the Vivarium? That is the old exhaust blower number 5. It handles the exhaust for the main lab.

Thanks,

Jim Hanchett
Amherst Drug Lab
Room N251 Morrill I
637 North Pleasant Street
Amherst, MA 01003
Phone 413-545-2607
Fax 413-545-2608
Cell [REDACTED]